

## Technical Datasheet Input / Output Modules with Modbus RTU Protocol with RS485 Interface

The IO modules communicate via RS485. The port can drive distances up to max 700 meters without the use of any repeater (*this feature however also depends on the signal strength of the Modbus Master Device*).

The RS485 Digital IO module is sturdy, low power usage and easy to use.

### 8 Port DO Module: -



The IO modules are mounted on DIN rail mountable casing and with exposed connectors and LED indicators. The DIP switch for Slave ID and Baud rate are placed inside the enclosure.

The design of the modules incorporates '**resettable Fuses**' to safeguard against reverse polarity connection both for **Power** and **Communication** port.

## Specifications

### General –

<b>I/O Connectors</b>	12 Pin 5.08 mm pitch pluggable screw Terminal Block
<b>Dimensions</b>	110 mm L x 110 mm B x 50 mm H
<b>BPower</b>	Input Power – 15-40 VDC or 24 V AC / DC options Typical – 12V DC @ 150mA

**Operating Temperature** 0 – 60° C (32 ~ 140°F)  
**Storage Temperature** -20 - 70° C (-4 ~ 158°F)  
**Storage Humidity** 5 ~ 95 % RH, non – Condensing

**Certifications****Relay Output –**

**Channels** 8  
**Contact Form** 1A, 1C  
**Contact Material** Ag Alloy  
**Contact Capacity** 10A @ 240VAC, 10A @ 28VDC  
**Coil Voltage** 5 – 48 VDC  
**Coil Power** 0.36 W  
**Insulation Resistance** 250MΩ  
**Electrical Life** 1 x 10<sup>5</sup>  
**Mechanical Life** 1 x 10<sup>7</sup>  
**Operating Time** 7 msec, Max 15 msec  
**Release Time** 2 msec, Max 6 msec

**Additional Features: -**

Communication ports are isolated  
Input power reverse polarity safety  
ESD Safety IEC 61000-4-2, ± 30KV contact, ± 30KV air  
EFT IEC 61000-4-4, 50A (5/50ms)  
400V isolation.  
CRC Error check.  
No configuration needed on the IO board

**Configuration Settings: -**

**Communication Speed** 9600 – 115200 Kbps (DIP SW selectable)  
**Data Bits** 8  
**Parity** None  
**Stop bit** 1  
**CRC** Yes  
**Slave ID** DIP SW selectable  
**Function code** 0x05 and 0x0F (5 Single coil & 15 multiple coil)  
**DO Register Address** 0,1,2,3,4,5,6,7.


ID	Function Description	Register Description	Modbus Function Code	Protocol	Data Type
1	DO 1	00001	0X05,0X0F	RS485	1 Bit Boolean
2	DO 2	00002	0X05,0X0F	RS485	1 Bit Boolean
3	DO 3	00003	0X05,0X0F	RS485	1 Bit Boolean
4	DO 4	00004	0X05,0X0F	RS485	1 Bit Boolean
5	DO 5	00005	0X05,0X0F	RS485	1 Bit Boolean
6	DO 6	00005	0X05,0X0F	RS485	1 Bit Boolean
7	DO 7	00007	0X05,0X0F	RS485	1 Bit Boolean
8	DO 8	00008	0X05,0X0F	RS485	1 Bit Boolean

### Note: -


For MODBUS communications, a **shielded and twisted pair cable** is used. One example of such cable is Belden 3105A.

### Recommended Cable Electrical Characteristics: -

**22 AWG Cable**                      Shielded Twisted pair should be used  
**Tinned Copper**                      Recommended  
**Nominal Conductor DCR** 14.7 ohm / 1000 ft  
**Nominal Capacitance**    11 pf / feet (conductor to conductor)  
**High Frequency Non-Insertion Loss**    0.5db / 100f




### BAUD RATE DESCRIPTION



- For Baud rate Selection, DIP SW is used as per the diagram.
- Pulling up the switch will make Baud rate active.
- If no selection is made 9600 will be default Baud rate.
- When u change the Baud rate in the Module power 'ON' condition, pls press the reset button to get Change to affect.

Baud Rate	DIP SWITCH			
	1	2	3	4
9600	OFF	OFF	OFF	OFF
19200	ON	OFF	OFF	OFF
38400	OFF	ON	OFF	OFF
57600	OFF	OFF	ON	OFF
115200	OFF	OFF	OFF	ON

### SLAVE ID DESCRIPTION



For Slave ID Selection SW is used to Set The SLAVE ID .

For Slave ID DIP Switch **LSB is "1"** follow through **"4" is MSB**.

Slave ID Confirmed through below Device ID table .

IF Eg. Slave ID 1 is Needed to be selected Switch number 1 should pulled up other three should be selected down side. So"1 0 0 0" will be selected as Slave ID 1.

Slave ID	DIP SWITCH				OUTPUT (Binary)	OUTPUT (Decimal)
	1	2	3	4		
0	OFF(0)	OFF(0)	OFF(0)	OFF(0)	1 0 0 0	1

<b>1</b>	ON(1)	OFF(0)	OFF(0)	OFF(0)	<b>1 0 0 0</b>	<b>1</b>
<b>2</b>	OFF(0)	ON(1)	OFF(0)	OFF(0)	<b>0 1 0 0</b>	<b>2</b>
<b>3</b>	ON(1)	ON(1)	OFF(0)	OFF(0)	<b>1 1 0 0</b>	<b>3</b>
<b>4</b>	OFF(0)	OFF(0)	ON(1)	OFF(0)	<b>0 0 1 0</b>	<b>4</b>
<b>5</b>	ON(1)	OFF(0)	ON(1)	OFF(0)	<b>1 0 1 0</b>	<b>5</b>
<b>6</b>	OFF(0)	ON(1)	ON(1)	OFF(0)	<b>0 1 1 0</b>	<b>6</b>
<b>7</b>	ON(1)	ON(1)	ON(1)	OFF(0)	<b>1 1 1 0</b>	<b>7</b>
<b>8</b>	OFF(0)	OFF(0)	OFF(0)	ON(1)	<b>1 0 0 0</b>	<b>8</b>
<b>9</b>	ON(1)	OFF(0)	OFF(0)	ON(1)	<b>1 0 0 1</b>	<b>9</b>
<b>10</b>	OFF(0)	ON(1)	OFF(0)	ON(1)	<b>1 0 1 0</b>	<b>10</b>
<b>11</b>	ON(1)	OFF(0)	ON(1)	ON(1)	<b>1 0 1 1</b>	<b>11</b>
<b>12</b>	OFF(0)	OFF(0)	ON(1)	ON(1)	<b>1 1 0 0</b>	<b>12</b>
<b>13</b>	ON(1)	OFF(0)	ON(1)	ON(1)	<b>1 1 0 1</b>	<b>13</b>
<b>14</b>	OFF(0)	ON(1)	ON(1)	ON(1)	<b>1 1 1 0</b>	<b>14</b>
<b>15</b>	ON(1)	ON(1)	ON(1)	ON(1)	<b>1 1 1 1</b>	<b>15</b>

**Contact us: -**

**Augmatic Technologies Pvt. Ltd.,  
 Plot no 6, Shah Industrial Estate II,  
 Kotambi,  
 Vadodara – 391510.  
 Email – Sales@wittelb.com**